



View Notice Details

Notice Type CCO Critical
Notice Identifier 8000
Notice Name CCO - 17:53 100713 Potential Critical Contingency
Published 13/07/2010 17:53
Begin Date & Time 13/07/2010 17:53
End Date & Time 15/07/2010 23:59
Notice Period 2
Required Response Indicator Advice Only

Detail 13/07/2010
Notification of Potential Critical Contingency

The CCO has determined that a potential Critical Contingency situation exists.

1. Event causing potential critical contingency

Unplanned Pohokura outage and consequential falling linepack and pressure across the system

2. Areas of transmission system affected

All areas

3. Summary of actions being taken to resolve event

MDL and Vector are operating under the MPOC and VTC

Notes:

(a) TSOs will continue to take action under the VTC/MPOC with the objective of regaining balance and preventing a Critical Contingency from occurring.

(b) The potential Critical Contingency will be terminated when the CCO either issues a Notification of Termination of Potential Critical Contingency or when a Critical Contingency is declared upon which the potential Critical Contingency is automatically terminated.

(c) The communication of this notice by email is recorded on the CCO computer system and the notice is considered received by this record. The date and time of this notice is that time stamped by the CCO computer system. It is not required to reply to or acknowledge this email notice.

(d) This notice will be communicated by a truncated SMS message.

(e) This notice will be published on the CCO internet site in the public domain. Refer to <https://www.oatis.co.nz>

(f) The CCO will notify the TSOs by telephone of this notice.
Sent by the Critical Contingency Operator

[Previous](#)