



View Notice Details

Notice Type CCO Critical
Notice Identifier 13563
Notice Name CCO - 22:50 Termination of Potential Critical Contingency
Published 12/07/2012 22:49
Begin Date & Time 12/07/2012 22:46
End Date & Time 13/07/2012 23:59
Notice Period 1
Required Response Indicator Action Required

Detail 12/07/2012
Termination of Potential Critical Contingency

The CCO has determined that potential Critical Contingency conditions have been terminated.

1. Event that caused potential Critical Contingency

Oaonui Production Station stopped production between 00:10 and 00:20 hours today as a result of critical control valve failure on the Oaonui Production Station.

2. Areas of transmission system affected

All areas of the transmission system.

3. Details regarding resolution of event

The TSO has advised the CCO that the Oaonui Production Station was returned to service at 21:40 hours. The CCO has monitored the transmission system since that time and is satisfied that the potential critical contingency conditions have been resolved.

Accordingly, the potential critical contingency is terminated.

Notes:

(a) The communication of this notice by email is recorded on the CCO computer system and the notice is considered received by this record. The date and time of this notice is that time stamped by the CCO computer system. It is not required to reply to or acknowledge this email notice.

(b) This notice will be communicated by a truncated SMS message.

(c) This notice will be published on the CCO internet site in the public domain. Refer to <https://www.oatis.co.nz>

(d) The CCO will notify the TSOs by telephone of this notice.
Sent on behalf of the Transmission System Owner by the Critical Contingency Operator

[Previous](#)