

## Critical Contingency Termination Notice

<b>Date:</b>	24 May 2016
<b>Time:</b>	23:00 Hours
<b>Notice Number:</b>	CC-0024
<b>Notice Type:</b>	<b>Critical Contingency Termination</b>
<b>Notice Issued To:</b>	<b>First Gas &amp; MDL TSO</b> <b>Stakeholders listed in Information Guide</b> <b>Interested Parties</b>
<b>CCO Instruction to TSO:</b> <b>[First Gas &amp; MDL]</b>	The Critical Contingency has been terminated.  Issue notice of Termination of Critical Contingency to Large Consumers and Retailers within 30 minutes and ensure an appropriate critical notice is posted on OATIS and direct retailers to advise their consumers that the critical contingency has been terminated.
<b>Critical Contingency Termination Time &amp; Date:</b>	23:00 hours on 24 May 2016
<b>Current Status:</b>	The CCO has determined that the Critical Contingency situation has been resolved.  Pohokura Production Station has returned to normal flows and the linepack level in the Maui pipeline has improved and stabilised.
<b>Event that caused Critical Contingency:</b>	Pohokura Production Station tripped due to a power outage. Maui pipeline linepack dropped rapidly and the critical contingency pressure threshold at Kapuni was subsequently breached.
<b>Details of Event resolution:</b>	STOS restarted Pohokura Production Station and have returned to normal production levels. Further to issuing the Critical Contingency Declaration Notice, other producers responded and increased production levels and gas storage ceased storing gas.
<b>CCO determination on Regional Critical Contingency Status:</b>	Non-Regional
<b>Areas of transmission system affected:</b>	Maui Pipeline System

This notice is issued pursuant to **Regulation 60** of the Gas Governance (Critical Contingency Management) Regulations 2008 and amendments. All directions issued by the CCO pursuant to this declaration must be complied with.

This notice is issued in accordance with the General Critical Contingency Notice Conditions contained in the CCO Information Guide, CCO Communications Plan, First Gas CCMP and MDL CCMP.

The CCO will issue advice of this Notice of Critical Contingency Termination to the stakeholders listed in the CCO Information Guide and publish this notice in the public domain of the CCO web site at <http://www.cco.org.nz>